



3130 East Main St., Springfield, OH 45503, Suite 1A | Phone: 937.521.2160 | Email: kvanzant@clarkcountyohio.gov

Date: March 22, 2023

Subject: 115 S. Persimmons St. Catawba, OH 43010
Catawba School Demolition/Blight Removal Re-Bid 1
Clark County, Ohio PY2023 BDSR

Bid Date: March 27, 2023

Dear Prospective Bidder:

Enclosed please find Addendum No. 1 dated March 22, 2023:

- Answer to question regarding fill material.

Please acknowledge your receipt of this Addendum on your bid submittal.

If you have any questions, please contact me via email.

Best Regards,

A handwritten signature in black ink, appearing to read "Kara Van Zant", written in a cursive style.

Kara Van Zant
Development Project Coordinator
3130 E. Main Street, Suite 1A
Springfield, Ohio 45503
Email: kvanzant@clarkcountyohio.gov

Enclosures: Addendum No. 1



Addendum No. 1

Date: March 22, 2023

Subject: 115 S. Persimmons St. Catawba, OH 43010
Catawba School Demolition/Blight Removal Re-Bid 1
Clark County, Ohio PY2023 BDSR

Bid Date: March 27, 2023

SECTION I: Technical Specifications

Question:

Is the stone, making up the driveway and parking lot, acceptable to be used as fill material and be buried following demolition?

Engineer's Answer:

The current specification would not allow for the stone to just be buried on site. Clean fill is defined as clay material. That specification calls out specifically that the fill should be free from stone material.

End of Addendum No. 1